



Glo-Quartz® Incorporated
 1550 S. Euclid Ave., Tucson, AZ 85713
 520-792-2331 1-800-423-4078
info@gloquartz.com

DESCRIPTION OF HEATERS	KW	IMMERSION (IN)	PHASE	COMPATABLE			
				240V	480V		
				208/240V CONTROLLER	440/480V CONTROLLER		
3" 304 SS SCREWPLUG (6) .440" 304 SS ELEMENTS NEMA 1 TERMINAL HOUSING 20 W/SQ.IN.	3	11	1	P3SA-3DD11-E1	T2A	P3SA-3II11-E1	T2A
	4.5	16	1	P3SA-45DD16-E1	TC1-350	P3SA-45II16-E1	TC1-3430
	6	20	1	P3SA-6DD20-E1		P3SA-6II20-E1	
	7.5	25	1	P3SA-75DD25-E1	P3SA-75II25-E1		
	9	29	1	P3SA-9DD29-E1	P3SA-9II29-E1		
	12	38	3	P3SA-12EE38-E1	TC1-330	P3SA-12JJ38-E1	
15	47	3	P3SA-15EE47-E1	TC1-350	P3SA-15JJ47-E1		

ALTERNATE VOLTAGE CODES, REPLACE BLUE LETTERS IN THE P/N WITH CODES BELOW	
A=120/1	HH=415/3
B=208/1	I=440/1
C=208/3	J=440/3
D=220/1	Q=460/1
E=220/3	QQ=460/3
BB=230/1	II=480/1
CC=230/3	JJ=480/3
DD=240/1	K=550/1
EE=240/3	L=550/3
F=277/1	KK=575/1
G=380/1	LL=575/3
H=380/3	M=600/1
GG=415/1	N=600/3

THE CONTROLLERS HAVE AN ANALOG 60-250F STAT, FOR DIGITAL CHANGE TC1 TO TCD
 SEE "THERMOSTATS AND TERMINAL BOX OPTIONS" PAGE FOR OTHER HOUSING VARIATIONS

DESCRIPTION OF HEATERS	KW	IMMERSION (IN)	PHASE	COMPATABLE			
				240V	480V		
				208/240V CONTROLLER	440/480V CONTROLLER		
3" 304 SS SCREWPLUG (6) .440" 316 SS ELEMENTS NEMA 1 TERMINAL HOUSING 20 W/SQ.IN.	3	11	1	P3SB-3DD11-E1	T2A	P3SB-3II11-E1	T2A
	4.5	16	1	P3SB-45DD16-E1	TC1-350	P3SB-45II16-E1	TC1-3430
	6	20	1	P3SB-6DD20-E1		P3SB-6II20-E1	
	7.5	25	1	P3SB-75DD25-E1	P3SB-75II25-E1		
	9	29	1	P3SB-9DD29-E1	P3SB-9II29-E1		
	12	38	3	P3SB-12EE38-E1	TC1-330	P3SB-12JJ38-E1	
15	47	3	P3SB-15EE47-E1	TC1-350	P3SB-15JJ47-E1		



Glo-Quartz® Incorporated
 1550 S. Euclid Ave., Tucson, AZ 85713
 520-792-2331 1-800-423-4078
info@gloquartz.com

DESCRIPTION OF HEATERS	KW	IMMERSION (IN)	PHASE	COMPATABLE			
				240V	480V		
				208/240V CONTROLLER	440/480V CONTROLLER		
3" 304 SS SCREWPLUG (6) .440" ALLOY 800 ELEMENTS NEMA 1 TERMINAL HOUSING 20 W/SQ.IN.	3	11	1	P3N-3DD11-E1	T2A	P3N-3II11-E1	T2A
	4.5	16	1	P3N-45DD16-E1	TC1-350	P3N-45II16-E1	TC1-3430
	6	20	1	P3N-6DD20-E1		P3N-6II20-E1	
	7.5	25	1	P3N-75DD25-E1	P3N-75II25-E1		
	9	29	1	P3N-9DD29-E1	P3N-9II29-E1		
	12	38	3	P3N-12EE38-E1	TC1-330	P3N-12JJ38-E1	
15	47	3	P3N-15EE47-E1	TC1-350	P3N-15JJ47-E1		

THE CONTROLLERS HAVE AN ANALOG 60-250F STAT, FOR DIGITAL CHANGE TC1 TO TCD
 SEE "THERMOSTATS AND TERMINAL BOX OPTIONS" PAGE FOR OTHER HOUSING VARIATIONS

ALTERNATE VOLTAGE CODES, REPLACE BLUE LETTERS IN THE P/N WITH CODES BELOW	
A=120/1	HH=415/3
B=208/1	I=440/1
C=208/3	J=440/3
D=220/1	Q=460/1
E=220/3	QQ=460/3
BB=230/1	II=480/1
CC=230/3	JJ=480/3
DD=240/1	K=550/1
EE=240/3	L=550/3
F=277/1	KK=575/1
G=380/1	LL=575/3
H=380/3	M=600/1
GG=415/1	N=600/3